

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-0075:103 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: Lawrence Flood (203) 484-1200

**DESIGN:** Model BG10, -10A, -10L, -10N, -10P, -10T, -10WP; BG-10LX\*, BG-10SP, BGID, BGX-10, -10L; BG-1; HR10, -10A; HRA-10, ARA-10 and AR-10F manual pull stations. Model BG-10WP is suitable for outdoor use when installed with outdoor backbox and gasket. Models HR-10 and HR-10A are suitable for halon extinguishing systems. All models are intended for indoor use and must be mounted on Model SB-10 or SBA-10\* back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed electrically and functionally compatible fire alarm control units.

\*Rev. 03-20-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**